



NOTES:

1. 4" TYPICAL, 6" DEPTH IF IN ROCK.
2. FOUNDATION STONE REQUIRED WHEN SOIL CONDITIONS ARE UNSTABLE.
3. CLEAR DISTANCE NOT LESS THAN 6" OR MORE THAN 12" EACH SIDE.
4. INITIAL BACKFILL SHALL BE PLACED IN 6" LIFTS AND COMPACTED. INITIAL BACKFILL SHALL CONTAIN NO MATERIAL OVER 1 1/2" IN DIAMETER, FROZEN LUMPS, OR DEBRIS.
5. BACKFILL SHALL BE COMPACTED TO 95% STANDARD PROCTOR DENSITY UP TO 1' BELOW SUBGRADE. REFER TO ROADWAY STANDARD FOR FINAL 1'.
6. PVC PIPE MATERIAL SHALL BE ASTM 03034 WITH A DR OF 26 OR LESS, OR AWWA C900 DR 18.



TOWN OF MOORESVILLE

STANDARD DETAIL

SEWER SYSTEMS
**PVC SEWER
 PIPE BEDDING**
 (UP TO 15" DIAMETER)

January 2014
 Revision 2

NTS

S - 13.0